



Notes:

1. All conduit is to be PVC electrical conduit, schedule 40
2. All conductor below grade will be of the direct buried type.
3. Customer furnishes and installs all material, including underground meter base, pole, and conductor from the meter base to pedestal.
4. WFECA will connect conductor to secondary pedestal, consumer will furnish conductor.
5. The minimum post size is 6" round or 4" square

Disclaimer: This document is intended as a guideline for underground meter loop construction. Actual construction of meter service shall comply with the latest version of the National Electrical Code, the National Electrical Safety Code and any Federal, State, County or Municipal Codes, which ever is more stringent. Contact the Authority Having Jurisdiction (NEC 80.13) or its designated representative for specific details.

Guide for Temporary Underground Meter Base Loop Pole at Secondary Pedestal		
2005	WFECA	GS-9C